

Approved For Release 2002/06/24 : CIA-RDP99B00048R000100060019-2

SECRET

(When Filled In)

FILE INFO

REPRODUCTION PROHIBITED

| ACTION | 1 | 6 | 11 | 16 |
|--------|---|----|----|----|
| | 2 | 7 | 12 | 17 |
| | 3 | 8 | 13 | 18 |
| | 4 | 9 | 14 | 19 |
| | 5 | 10 | 15 | 20 |

S E C R E T 241244Z APR 74 CITE [REDACTED]

25X1A

25X1A IMMEDIATE [REDACTED]

25X6 IDEALIST - [REDACTED]

SUBJ: JPTS FUEL TEST

1. FUEL SAMPLES WERE TESTED IN LOCAL LABORATORY THIS DATE AND FOUND TO MEET SPECIFICATIONS IN ALL CASES. THE FOLLOWING DATA IS PROVIDED FOR YOUR INFORMATION:

| | SAMPLE ONE | SAMPLE TWO |
|--------------------|------------|------------|
| FLASH POINT | 135 DEG F | 135 DEG F |
| FSII | 0.14 | 0.14 |
| WATER CONTENT | NONE | NONE |
| A.P.I. GRAVITY | 48.1 | 48.2 |
| PARTICULATE MATTER | 0.03 MG/L | 0 |

TWO SAMPLES WERE USED. ONE WAS TAKEN FROM FUEL LINE, THE OTHER FROM THE BOTTOM DRAIN POINT.

2. THE LABORATORY HERE IS THE MAIN CENTRAL FACILITY WHICH SERVICES THE ENTIRE MEDITERRANEAN [REDACTED] ALL CHEMISTS ARE DEGREED CIVILIANS WHO ARE HIGHLY SKILLED. THREE DIFFERENT CHEMISTS, WORKING INDEPENDENTLY, CAME UP WITH FIGURES WHICH WERE IN OTAL AGREEMENT. THEIR ANALYSIS INDICATES THE FUEL MAY BE USED WITHOUT RESERVATION. IT FURTHER INFORMATION IS NEEDED, PLEASE ADVISE.

25X1C

E-2 IMPDET

S E C R E T